



Jim Doyle, Governor  
Jack L. Fischer, A.I.A., Secretary

August 25, 2008

INFILTRATOR SYSTEMS INC.  
DAVID LENTZ  
6 BUSINESS PARK RD.  
PO BOX 768  
OLD SAYBROOK CT 06475

Re: Description: CHEMICAL OR PHYSICAL RESTORATION FOR POWTS  
Manufacturer: INFILTRATOR SYSTEMS INC.  
Product Name: AQUAWORX REMEDIATOR™  
Model Number(s): AQUAWORX REMEDIATOR™  
Product File No: 20080470

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code.  
**This approval is valid until the end of JUNE 2012.**

This approval is contingent upon compliance with the following stipulation(s):

- This product must be utilized in accordance with the manufacturer's printed installation instructions and this product approval. If there is a conflict between the manufacturer's installation instructions and the product approval, the product approval requirements will take precedence.
- The elevation of the system's infiltrative surface must be above the estimated highest groundwater elevation or bedrock by the distance prescribed in column entitled "Fecal Coliform >10000 cfu/100 ml" in Table Comm 83.44-3, Wis. Adm. Code.
- A copy of this approval letter and the manufacturer's printed installation instructions must be supplied to the buyer of this product.
- The outlet baffle of the septic tank, which has this product installed, must have installed an effluent filter capable of filtering particles of 1/8 inch in size or larger.
- This product must be installed by a properly licensed plumber.
- A state Sanitary Permit must be obtained when this product is installed.
- This product must be maintained at least annually.

This approval supersedes the approval issued on 6/22/2007 under product file number 20070262. This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20070262. The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Product Reviewer  
Commerce; Safety & Buildings Div.; PO Box 2658; 201 W Washington Ave.; Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456; E-mail: Jean.MacCubbin@wisconsin.gov